

Energy Consumption and Emissions in Small and Medium-Sized Industry

K. H. Tiedemann, BC Hydro

ABSTRACT

The industrial sector uses about forty percent of the electricity, natural gas and residual fuel oil consumed in Canada, and it is thus a major contributor to Canadian emissions of greenhouse gases. A major Canadian government initiative to reduce industrial sector greenhouse gas emissions is the Dollars to Sense program. This program provides small and medium-sized Canadian businesses with a set of three workshops that help participants find and implement energy cost savings measures and reduce emissions. This study found that the Dollars to Sense program led to annual industrial energy savings of 3,186 TJ and annual emissions reductions of 197 kilotonnes of carbon dioxide equivalent.

Introduction

The industrial sector uses about forty percent of the electricity, natural gas and residual fuel oil consumed in Canada, and it is thus a major contributor to Canadian emissions of greenhouse gases. Major uses of electricity, natural gas and residual fuel oil in Canadian industry include water and process heat, space conditioning, process cooling and refrigeration, fans, pumps, compression, conveyance, electro-chemical processes, lighting and a wide variety of motor systems. A major Canadian government initiative to reduce industrial sector greenhouse gas emissions is the Dollars to Sense program. This program provides small and medium-sized Canadian businesses with a set of three workshops that help participants identify, plan, implement and monitor energy cost savings measures and reduce emissions. In summary, the purpose of the Dollars to Sense program is to help participants find and implement energy savings measures and address climate change issues.

Dollars to Sense includes three coordinated workshops for energy managers, energy services professionals and senior decision makers. The workshops are administered by Natural Resources Canada (NRCan) but delivered by private sector energy professionals. The structure and content of the workshops are periodically reviewed and modified in response to evolving client requirements and needs. In addition, customized workshops for participants in a single facility are offered.

A brief summary of the three workshops is as follows. In the Energy Master Plan Workshop, participants learn to develop and implement a comprehensive energy management plan including assembling an appropriate team, using financing options and developing cost-effective energy solutions. In the Energy Monitoring and Tracking Workshop, participants learn to save money on energy costs by collecting data, developing an energy use baseline, analyzing energy use and establishing and implementing an improvement plan. In the Spot the Energy Savings Opportunities Workshop, participants learn to identify and capitalize on immediate savings opportunities including reviewing energy basics, identifying opportunities in electrical and thermal processes and assessing and quantifying benefits. Some 2,000 industrial sector representatives have attended one or more Dollars to Sense workshops.

This paper reports on discrete choice modeling and engineering analysis that was used to estimate the impact of the Dollars to Sense program. The program impacts examined include

retrofit actions undertaken, energy savings due to these actions, and consequent reductions in greenhouse gas emissions in the Canadian industrial sector.

Background and Method

A number of recently published studies examine energy use in industrial facilities. BC Hydro 1991a, 1991b, and 1991c examine overall energy use as well as key technologies including fans, pumps and motors. Friedman 2001 provides similar information for California industrial energy use. Industry Canada 1996 and Jaccard et al 2003 examine opportunities for energy efficiency in Canadian industry. Taken as a group, these studies have found that the industrial sector has a number of cost-effective technologies which can reduce energy use and greenhouse gas emissions.

Since large industrial establishments often have on-site energy managers and specialized in-house engineering expertise, the Dollars to Sense program has focused on small and medium-sized establishments (SME). Because the program's industrial participants were typically small and medium-sized establishments, it was agreed that the focus of the study would be on industrial establishments with 500 employees or fewer. Focus groups were held in Montreal and Toronto to better understand how energy use decisions are made, the factors affecting these decisions, and the key technologies installed as a result of program participation.

Following a detailed literature review and interviews with program managers and staff, five main substantive issues were identified for study. The issues were:

- (1) estimate industrial sector energy consumption by facility, by end use and by fuel;
- (2) develop gross measure savings rates for the most important energy saving technologies;
- (3) estimate the attribution rate or share of the market impacts on installation of energy saving technologies due to the program;
- (4) determine program impact on energy savings due to installation of energy savings technologies; and
- (5) determine program impact on greenhouse gas emissions in terms of kilotonnes of carbon dioxide equivalent.

Table 1. Issues, Data Source and Methodologies

Study Issue	Data Sources	Methodologies
Estimate end use consumption	Customer survey NRCan and DOE data Focus groups	Engineering algorithms
Develop gross measure savings estimates	File review Literature review Focus groups	Engineering algorithms
Estimate attribution rates	Customer survey NRCan data	Logit regression
Determine energy savings	Customer survey NRCan data	Engineering algorithms
Determine emission savings	Customer survey NRCana data	Engineering algorithms

Analysis

The initial step was the development of detailed end use consumption estimates for small and medium-sized industrial establishments. Industry Canada provided information on energy consumption by facility type, facility size, information on energy shares by major end use, and total energy consumption per square meter. Since the end use information was more aggregated than desired for this analysis, the detailed spreadsheets from United States Department of Energy were used to develop energy consumption shares for thirteen end uses. The resulting estimated end use shares were then checked with experts from the Office of Energy Efficiency to ensure that they were reasonable.

Table 2 provides estimates of consumption in GJ per year and consumption shares as decimal fractions. Average consumption for the facilities was about 101,858 GJ per year with the main end uses including other machine drives (25,913 GJ per year), pumps (12,795 GJ per year), water and process heating (10,878 GJ per year), electro-chemical processes (10,614 GJ per year), space heating (7,975 GJ per year) and compressed air (7,007 GJ per year).

Table 2. Estimated SME Industrial Energy Consumption by End Use 2002

End Use	Consumption (GJ per year)	Share
Water and process heat	10,878	0.107
Cooking	1,020	0.010
Process cooling and refrigeration	6,264	0.062
Pumps	12,795	0.126
Fans and blowers	5,276	0.052
Compressed air	7,007	0.069
Conveyance	5,378	0.053
Other machine drives	25,913	0.254
Electro-chemical processes	10,614	0.104
Space heating	7,975	0.078
Space cooling	693	0.007
Facility lighting	6,804	0.067
Other uses	1,221	0.012
Total	101,858	1.000

The second step was the estimation of gross energy savings ratios. These ratios are estimates of the share of energy for that end use that will be saved on average through the installation of the efficient as opposed to the standard version of the technology. A wide variety of sources including Natural Resources Canada publications, technical reports on utility commission and program evaluation web sites, journal and conference literature and utility reports were reviewed to determine estimates of energy savings for key technologies. The gross measure savings ratio was estimated by the equation $\text{savings ratio}_i = (1 - \text{efficiency}_{st} / \text{efficiency}_{ef})$, where the savings ratio is the ratio applied to the end use consumption for a given measure and efficiency_{st} and efficiency_{ef} are the percentage efficiency levels of the standard and the efficient technologies for the relevant end use.

Table 3 provides estimates of savings by measure and by end use, for the most commonly used measures, as identified during focus groups with energy managers of industrial facilities held in Montreal and Toronto. In order to keep the customer survey manageable, emphasis was placed on those measures which were responsible for the bulk of expected savings. Note that the savings ratios vary substantially from a low of 0.042 for replacement of a less than 5 horse power

standard efficient motor with a high efficiency motor to a high of 0.750 for replacement of a type-A incandescent lamp with a CFL.

Table 3. Measure Savings

Measure	End Use	Standard Efficiency	High Efficiency	Savings Ratio
Drive/controls	Fans and blowers	Control vane 75%	ASD 95%	0.211
Fan motor 1-5HP	Fans and bowers	Standard 83.3%	High 87.5%	0.048
Drive/controls	Pumps	Control valve 80%	ASD 75%	0.158
Pump motor 6-25HP	Pumps	Standard 86.3%	High 95.1%	0.042
Drive/controls	Compressed air	Control throttle 83%	ASD 95%	0.126
Com motor 1-5HP	Compressed air	Standard 83.3%	High 87.5%	0.048
Reduce air leaks	Compressed air	Average leaks 75%	Reduced leaks 85%	0.118
Coupling/drive	Conveyance	Worm gear/v belt/helical 85%	ASD 75%	0.105
Con motor 6-25HP	Conveyance	Standard 86.3%	High 90.1%	0.042
Coupling/drive	Other process	Worm gear/v belt/helical 85%	ASD 95%	0.105
Other motor 6-25HP	Other process	Standard 86.3%	High 90.1%	0.042
Ovens	Cooking	Standard	Microwave	0.100
Mid-efficiency boiler	Space, process, water heat	Std efficiency 75%	Mid efficiency 85%	0.118
Hi-efficiency boiler	Space, process, water heat	Std efficiency 75%	High efficiency 95%	0.167
Mid-efficiency furnace	Space heating	Std efficiency 65%	Mid-efficiency 78%	0.167
Hi-efficiency furnace	Space heating	Std efficiency 65%	Condensing 90%	0.278
Economizer	Space cooling	No economizer	Air side economizer	0.100
Drive/controls	Refrigeration	Standard 85%	ASD 95%	0.105
CFL	Lighting	Type A 6%	CFL 24%	0.750
T8	Lighting	T12 24%	T8 25.5%	0.059
HID lamps	Lighting	Mercury vapor 15%	HID 30%	0.500
Roof insulation	Space heating	Std 0.95W/m ² /°C	Std 0.48W/m ² /°C	0.500
Wall insulation	Space heating	Std 0.70W/m ² /°C	Std 0.35W/m ² /°C	0.500

The third step was to estimate the impact of the program on installation of energy efficient technologies, using the following models, $install_i = F(\text{participant, industrial dummy, rate})$. $install_i$ takes the value 1 if measure i is installed, but it is 0 otherwise. Participant takes the value 1 for workshop participants but is 0 otherwise. Rate is the average rate paid by commercial customers by service territory in dollars per MWh equivalent. Industrial takes the value 1 if the customer is in the forestry, mining or manufacturing sectors but takes the value 0 otherwise. The equations were estimated using logit regression, with standard errors shown in parentheses, because ordinary least squares regression would provide biased estimates of customer installation decisions. It is worth noting that if p is the probability of installing an efficient technology, then the logit is given by the $\log(p/1 - p)$, and it is rather naturally referred to as the log of the odds ratio, since the odds ratio is the ratio of the probability of installing an efficient technology divided by the probability of not installing an efficient technology. Mathematically, the logit function is the inverse of the sigmoid or logistic function, which is commonly used to model diffusion of a new technology.

Table 4. Attribution Analysis

	Constant	Participation	Industrial	Electricity Rate	Chi-squared
Fans	-0.358 (0.873)	0.742 (0.268)	-1.155 (0.427)	-0.034 (0.014)	16.31 (0.001)
Pumps	-0.838 (0.706)	0.773 (0.257)	0.450 (0.388)	-0.015 (0.012)	10.91 (0.012)
Compressed air	-2.383 (0.997)	1.053 (0.335)	0.364 (0.456)	-0.001 (0.015)	13.13 (0.004)
Conveyance	-4.719 (1.631)	1.105 (0.544)	1.912 (0.730)	0.003 (0.025)	19.24 (0.000)
Other process	-2.335 (1.058)	0.789 (0.346)	0.393 (0.486)	-0.007 (0.106)	8.05 (0.045)
Efficient oven	-3.467 (1.515)	0.012 (0.510)	-0.026 (0.782)	0.001 (0.022)	0.11 (0.99)
Mid-efficiency boiler	-0.847 (0.880)	1.067 (0.294)	-1.949 (0.531)	-0.017 (0.014)	32.89 (0.000)
Hi-efficiency boiler	0.215 (1.063)	0.542 (0.334)	-2.869 (0.816)	-0.030 (0.017)	23.79 (0.000)
Mid-efficiency furnace	-0.544 (1.038)	0.956 (0.330)	-1.232 (0.519)	-0.030 (0.016)	15.08 (0.002)
Hi-efficiency furnace	-0.400 (1.437)	0.822 (0.448)	1.265 (1.138)	-0.039 (0.023)	23.60 (0.000)
Economizer	-0.773 (0.851)	0.308 (0.272)	-0.634 (0.428)	-0.015 (0.013)	3.58 (0.311)
Efficient refrigeration	-2.206 (0.892)	1.221 (0.312)	0.585 (0.428)	-0.002 (0.014)	19.66 (0.000)
CFL	-0.449 (0.659)	1.614 (0.221)	-0.925 (0.334)	-0.001 (0.010)	67.02 (0.00)
T8	0.464 (0.681)	1.606 (0.228)	-1.643 (0.353)	-0.021 (0.011)	76.86 (0.00)
HID lamps	-0.957 (0.692)	0.914 (0.226)	0.004 (0.336)	-0.001 (0.013)	17.69 (0.001)
Roof insulation	-1.876 (0.860)	0.490 (0.285)	-0.290 (0.435)	-0.001 (0.013)	3.68 (0.298)
Wall insulation	-2.765 (0.957)	0.759 (0.326)	-0.012 (0.473)	0.005 (0.014)	5.95 (0.114)

The fourth step was the estimation of energy savings. Energy savings were estimated for each measure where energy savings for measure *i* is the product of the use rate, the savings rate, the partial effect as calculated from the logit model and the number of participants. Note that the partial effect or the estimated impact of program participation on the install decision is the partial derivative of the likelihood with respect to the program participation variable in the equations in Table 3 above. Table 4 provides estimated energy savings in gigajoules (GJ) for each measure and end use examined. Note that for lighting products savings are adjusted for the assumed share of connected lighting load of 0.100 for screw type lamps, 0.800 for linear fluorescent tubes and 0.100 for high intensity discharge lighting. Note also that for insulation products savings are adjusted for the assumed share of heat loss of the opaque components of 0.500 for walls and 0.500 for roofs. Total measure savings were 3,186.2 TJ. The most important measures and their savings included mid-efficiency boilers (421.9 TJ), efficient fan systems (219.6 TJ), efficient pump systems (473.3 TJ), efficient compressed air systems (319.5 TJ), CFLs (307.8 TJ), other process equipment (398.5 TJ) and T8 tubes (199.2 TJ).

Table 5. Energy Savings Analysis

Measure	End use	End Use per Facility (GJ)	Savings Rate	Partial Effect	Number of Participants	Energy Savings (TJ)
Efficient fans and motors	Fans	5,276	0.259	0.106	1,516	219.6
Pumps and motors	Pumps	12,795	0.200	0.122	1,516	473.3
Compression, leaks, motors	Compression	7,007	0.292	0.103	1,516	319.5
Conveyance and motors	Conveyance	5,378	0.147	0.032	1,516	38.4
Other process and motors	Other process	25,913	0.147	0.069	1,516	398.5
Efficient oven	Oven	1,020	0.100	0.004	1,516	0.7
Mid-eff boiler	Space, water, [process heat	18,853	0.118	0.125	1,516	421.9
Hi-eff boiler	Space, water, process heat	18,853	0.167	0.040	1,516	188.5
Mid-furnace	Space heating	7,975	0.167	0.092	1,516	185.1
Hi-furnace	Space heating	7,975	0.278	0.003	1,516	8.7
Chiller	Space cooling	693	0.100	0.042	1,516	4.4
Hi-efficiency refrigerator	Process cool	6,264	0.105	0.142	1,516	141.5
CFL	Lighting	6,804	0.075	0.398	1,516	307.8
T8	Lighting	6,804	0.050	0.386	1,516	199.2
HID	Lighting	6,804	0.047	0.189	1,516	91.6
Roof insulate	Space heating	7,957	0.038	0.061	1,561	28.1
Wall insulate	Space heating	7,957	0.176	0.075	1,516	159.4
Total						3,186.2

The fifth step was the estimation of emissions savings, which were measured in terms of kilotonnes of carbon dioxide equivalent. This is a useful summary measure that aggregates the impacts of the various emissions produced through the use of a particular energy source or fuel. Carbon dioxide savings, disaggregated by fuel for the *i*th measure, are the product of energy savings for the measure multiplied by the fuel specific emission factor.

The emission factors, which were supplied by Natural Resources Canada, are: (1) electricity – 64.23 tonnes of CO₂E per TJ; (2) natural gas – 50.45 tonnes of CO₂E per TJ; (3) fuel oil – 75.43 tonnes of CO₂E per TJ; and (4) fossil fuels – 56.79 tonnes of CO₂E per TJ. The latter estimate is based on a fuel split of 74.6% natural gas and 25.4% fuel oil. Disaggregated information was not available which would allow a more detailed breakdown between natural gas and residual fuel oil by end use.

Total annual emissions reductions were 197.4 kilotonnes of CO₂. The most important measures and their savings included mid-efficiency boilers (24.0 kilotonnes of CO₂), efficient fan systems (14.1 kilotonnes of CO₂), efficient pump systems (30.4 kilotonnes of CO₂), efficient compressed air systems (20.5 kilotonnes of CO₂), CFLs (19.8 kilotonnes of CO₂), other process equipment (25.6 kilotonnes of CO₂) and T8 tubes (12.8 kilotonnes of CO₂).

Table 6. Emissions Reduction Analysis

Measure	End Use	Energy Savings (TJ)	Main Fuel	Emissions Factor	Carbon Dioxide Reduction (kilotonnes)
Efficient fans and motors	Fans	219.6	Electricity	64.23	14.1
Pumps and motors	Pumps	473.3	Electricity	64.23	30.4
Compression, leaks, motors	Compression	319.5	Electricity	64.23	20.5
Conveyance and motors	Conveyance	38.4	Electricity	64.23	2.5
Other process and motors	Other process	398.5	Electricity	64.23	25.6
Efficient oven	Oven	0.7	Gas/oil	56.79	0.0
Mid-eff boiler	Space, water, process heat	421.9	Gas/oil	56.79	24.0
Hi-eff boiler	Space, process, water heat	188.5	Gas/oil	56.79	10.7
Mid-furnace	Space heating	185.1	Gas/oil	56.79	10.5
Hi-furnace	Space heating	8.7	Gas/oil	56.79	0.5
Chiller	Space cooling	4.4	Electricity	64.23	0.3
Hi-efficiency refrigerator	Process cooling	141.5	Electricity	64.23	9.1
CFL	Lighting	307.8	Electricity	64.23	19.8
T8	Lighting	199.2	Electricity	64.23	12.8
HID	Lighting	91.6	Electricity	64.23	5.9
Roof insulation	Space heating	28.1	Gas/oil	56.79	1.6
Wall insulation	Space heating	159.4	Gas/oil	56.79	9.1
		3,186.2			197.4

Summary and Conclusions

The study has three main conclusions as follows. First, average annual energy consumption for small and medium-sized industrial facilities was about 102,000 GJ per year with the main end uses including other machine drives (25,900 GJ per year), pumps (12,795 GJ per year), water and process heating (10,878 GJ per year), electro-chemical processes (10,600 GJ per year), space heating (8,000 GJ per year) and compressed air (7,000 GJ per year).

Second, total savings attributable to the Dollars to Sense program were 3,186.2 TJ. The most important measures and their savings included mid-efficiency boilers (421.9 TJ), efficient fan systems (219.6 TJ), efficient pump systems (473.3 TJ), efficient compressed air systems (319.5 TJ), CFLs (307.8 TJ), other process equipment (398.5 TJ) and T8 tubes (199.2 TJ).

Third, total annual emissions reductions attributable to the Dollars to Sense program were 197.4 kilotonnes of CO₂E. The most important measures and their savings included mid-efficiency boilers (24.0 kilotonnes of CO₂), efficient fan systems (14.1 kilotonnes of CO₂), efficient pump systems (30.4 kilotonnes of CO₂), efficient compressed air systems (20.5 kilotonnes of CO₂), CFLs (19.8 kilotonnes of CO₂), other process equipment (25.6 kilotonnes of CO₂) and T8 tubes (12.8 kilotonnes of CO₂).

References

- BC Hydro, 1991a. *Efficient Compressed Air Systems*. Vancouver, Canada: BC Hydro Power Smart.
- BC Hydro. 1991b. *High-Efficiency Motor Database*. Vancouver, Canada: BC Hydro Power Smart.
- BC Hydro. 1991c. *Pumping Profits*. Vancouver, Canada: BC Hydro Power Smart.
- Friedman, R. 2001, California Industry and Energy Efficiency. *Proceedings of the 2001 Energy Program Evaluation Conference*, 2001.
- Industry Canada and Natural Resources Canada. 1998. *Manufacturing Small to Medium-Sized Enterprises and Climate Change: A Review of Status, Barriers and Opportunities: Final Report*.
- Jaccard, M., J. Nyboer and A. Fogwill, How Big is the Electricity Conservation Potential In Industry? *Energy Journal*, Vol. 14, No. 2, 1993.
- Natural Resources Canada. 1996. *Industry Energy End-Use Analysis and Conservation Potential in Six Major Industries in Canada*.
- Natural Resources Canada. 2002. *CIPEC: Energy Efficiency Planning and Management Guide*.
- Office of Energy Efficiency. 2002, 2003, 2004, 2006, 2006. *Improving Energy Efficiency in Canada: Report to Parliament under the Energy Efficiency Act*.
- United States Department of Energy. 1998. Industrial End-Uses of Fuel Consumption. Table N6.4.